

# CERTIFICATE

Issued to:  
Applicant:  
**Eternalplanet Energy Co.,Ltd**  
27th Floor, Building 3A, Longgang Intelligent Park  
518116 Shenzhen Guangdong, China

Licensee:  
**Eternalplanet Energy Co.,Ltd**  
27th Floor, Building 3A, Longgang Intelligent Park  
518116 Shenzhen Guangdong, China

Product : Hybrid Energy Storage System  
Trade name(s) : ETERNALPLANET  
Type(s)/model(s) : EP Cube2 IEC-T-10G, EP Cube2 IEC-T-15G, EP Cube2 IEC-T-20G,  
EP Cube2 IEC-T-25G, EP Cube2 IEC-T-30G, EP Cube2 IEC-T-35G and  
EP Cube2 IEC-T-40G

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:  
- a type test according to VDE-AR-N 4105:2018 and DIN VDE V 0124-100:2020  
- an inspection of the factory location according to CENELEC Operational Document CIG 021  
- a DEKRA certification agreement with the number 6072186


DEKRA hereby grants the right to use the DEKRA Mark.

The DEKRA Mark may be applied to the product as specified in this certificate for the duration and under the conditions of the DEKRA Mark certification agreement.

This certificate is issued on 16 October 2025 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-165751

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



Cliff Lin  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



31-165751

**DEKRA Mark is the new KEMA-KEUR**

The DEKRA Mark certificate for this product is to all intents and purposes equivalent to a KEMA-KEUR certificate, the other certification mark used by DEKRA and should be valued and used as such. DEKRA Mark is gradually replacing KEMA-KEUR.

For more information please check: [Introducing DEKRA Mark](#)

**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: Hybrid Energy Storage System
Trade name(s)	: ETERNALPLANET
Type(s)/model(s)	: EP Cube2 IEC-T-10G, EP Cube2 IEC-T-15G, EP Cube2 IEC-T-20G, EP Cube2 IEC-T-25G, EP Cube2 IEC-T-30G, EP Cube2 IEC-T-35G and EP Cube2 IEC-T-40G
Type of NS protection	: Integrated NS protection
Assigned to Power generation unit type	: EP Cube2 IEC-T-10G, EP Cube2 IEC-T-15G, EP Cube2 IEC-T-20G, EP Cube2 IEC-T-25G, EP Cube2 IEC-T-30G, EP Cube2 IEC-T-35G EP Cube2 IEC-T-40G
Software version	: 0.1.4

**TESTS****Test requirements**

VDE-AR-N 4105:2018  
DIN VDE V 0124-100:2020

**Test result**

The test results are documented in DEKRA test file 621635500.

**Additional information**

This certificate is the NS protection certificate for Hybrid Inverter


The list of components is laid down in test report 6216355.51.

**Conclusion**

The examination has confirmed that all requirements were met.

**Factory location**

Shenzhen JingQuanHua & Everrise Intelligent Electric Co., Ltd.  
Jingquanhua Science and Technology Industrial Park, No.10 Pingqiao Road, Pingdi Street, Longgang District,  
518117 Shenzhen Guangdong, China

Trade name(s): Eternalplanet stands for:  ETERNALPLANET

The text "Trade name(s): Eternalplanet stands for:" is followed by a green infinity symbol logo and the word "ETERNALPLANET" in a bold, black, sans-serif font.

<b>E.7 Requirement for the NS protection test report (VDE-AR-N 4105:2018-11)</b>			
<b>E.7 Anforderungen an den Prüfbericht zum NA-Schutz</b>			
<b>Test report NS protection</b> <i>Prüfbericht NA-Schutz</i>			
<b>Type of NS protection:</b> <i>Typ NA-Schutz:</i>	<b>Integrated NS protection</b> <i>Integrierter NA-Schutz</i>		
<b>Software version:</b> <i>Software version:</i>	0.1.4		
<b>Manufacturer:</b> <i>Hersteller:</i>	Eternalplanet Energy Co., Ltd		
<b>Measuring period:</b> <i>Messzeitraum:</i>	<b>From 2025-08-16 to 2025-09-08</b> <i>Vom 2025-08-16 bis 2025-09-08</i>		
	<b>Inverter</b> <i>Umrichter</i>		
<b>Protection function</b> <i>Schutzfunktion</i>	<b>Setting tripping value</b> <i>Einstellwert</i>	<b>Measured tripping value</b> <i>Auslösewert</i>	<b>Measured tripping time</b> <i>Auslösezeit</i> <i>NA-Schutz</i>
<b>Rise-in-voltage protection <math>U &gt;&gt;</math></b> <i>Spannungssteigerungsschutz <math>U &gt;&gt;</math></i>	$1.25 * U_n$	286.29 V	136 ms
<b>Rise-in-voltage protection <math>U &gt;</math></b> <i>Spannungssteigerungsschutz <math>U &gt;</math></i>	$1.1 * U_n$	$1.1 * U_n$	$\leq 100 \text{ ms}^*$
<b>Voltage drop protection <math>U &lt;</math></b> <i>Spannungsrückgangsschutz <math>U &lt;</math></i>	$0.8 * U_n$	185.00 V	3040 ms
<b>Voltage drop protection <math>U &lt;&lt;</math></b> <i>Spannungsrückgangsschutz <math>U &lt;&lt;</math></i>	$0.45 * U_n$	103.22 V	358.1 ms
<b>Frequency decrease protection <math>f &lt;</math></b> <i>Frequenzrückgangsschutz <math>f &lt;</math></i>	47.5 Hz	47.50 Hz	132.0 ms
<b>Frequency decrease protection <math>f &gt;</math></b> <i>Frequenzsteigerungsschutz <math>f &gt;</math></i>	51.5 Hz	51.50 Hz	137.5 ms
<p>* The rise-in voltage protection as a running 10-minute mean value, Max. disconnecting time is 500s.            * Der anstiege Spannungsschutz als laufender 10-Minuten-Mittelwert, Max. TrennZeit beträgt 500.05s.</p> <p>The tripping time covers the period from the limit value violation <math>U/f</math> to the tripping signal to the interface switch.            Die Auslösezeit umfasst den Zeitraum von der Grenzwertverletzung <math>U/f</math> bis zum Auslösesignal an den Kuppelschalter.</p> <p>When planning the power generation system, the inherent time of the interface switch must be added to the highest time value determined above.            Bei der Planung der Erzeugungsanlage ist die Eigenzeit des Kuppelschalters zum höchsten oben ermittelten Zeitwert zu addieren.</p> <p>The switch-off time (total of the tripping time NS protection plus the inherent time of the interface switch) must not exceed 200 ms.            Die Abschaltzeit (Summe der Auslösezeit NA-Schutz zzgl. Eigenzeit des Kuppelschalters) darf 200 ms nicht überschreiten.</p>			
<input checked="" type="checkbox"/> <b>By integrated NS Protection</b> <i>Bei integriertem NA-Schutz</i>			
<b>Assigned to PGU type:</b> <i>Typ Erzeugungseinheit:</i>	EP Cube2 IEC-T-10G, EP Cube2 IEC-T-15G, EP Cube2 IEC-T-20G, EP Cube2 IEC-T-25G, EP Cube2 IEC-T-30G, EP Cube2 IEC-T-35G EP Cube2 IEC-T-40G		
<b>Integrated interface switch type:</b> <i>Typ integrierter Kuppelschalter</i>	Shenzhen Golden Electric Technology Co., Ltd., Relay: GTP-1A-12DCG		
<b>Interface switch own time with integrated NS protection</b> <i>Eigenzeit des Kuppelschalters bei integriertem NA-Schutz</i>	Operation time: 20 ms max; Release time: 10 ms max		
<p>The verification of the full function chain “NS protection- Interface switch” has yield to intended disconnection.            Die Überprüfung der Gesamtwirkungskette „integrierter NA-Schutz – Kuppelschalter“ führte zu einer erfolgreichen Abschaltung.</p>			